

Annexure - C

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 400/DW/PHD/EE-PA/2025

Dated: 07/11/2025

Thiru. N. Nagarajan, Junior Engineer, Water Supply(P), PHD, PWD, Puducherry, inspected the **Vivekanandha Vidyalaya, Sellaperumalpet, Lawspet, Puducherry - 605 008** on 08/09/2025 and on the basis of Water Test Report (Attached) bearing No. 2025/W-1014, dated 19.09.2025 & No. 2025/W-1191, dated 04.11.2025 of Water Testing Laboratory, PHD., PWD., Puducherry certified that the **Vivekanandha Vidyalaya** has safe drinking water facilities for the students and members of staff of the institution.

This certificate is valid till one Year

Signature with Seal :

Name

Er. C. VASSOU, M.E., ENV ENGG.,
EXECUTIVE ENGINEER
PUBLIC HEALTH DIVISION
PUBLIC WORKS DEPARTMENT
PUDUCHERRY.

Designation

PUBLIC WORKS DEPARTMENT
PUDUCHERRY.

To

The Correspondent,
Vivekanandha Vidyalaya,
Sellaperumalpet, Lawspet,
Puducherry - 605 008.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY



Report No. : TR/WTL/PHD/PWD/PDY/2025/W-1191
ULR-TC758025000000749F

Date: 05.11.2025

TEST REPORT- CHEMICAL

Page 1 of 1

Customer Name & Address : Vivekanandha Vidyalaya,
Sellaperumalpet, Lawspet, Puducherry - 605008.
Customer Reference : Letter dt.04.11.2025

SAMPLE DETAILS

Sample Code	: 2025/W-1191	Information provided by the Customer	
Product Category	: Water	Sampled on	: 04.11.2025
Sample Name	: Drinking Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - V
Sample Received on	: 04.11.2025	Sampling Location	School Campus, Sellaperumalpet, Lawspet, Puducherry.
Test Started on	: 04.11.2025		
Test Completed on	: 05.11.2025		

TEST RESULTS

CHEMICAL REPORT

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 24th Edition, 2023, 4500-H+B	--	6.24	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 24th Edition, 2023, 2510 B	µs/cm	251	---	---

.....End of Report.....

L. Anita Ben
Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY.

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No. : TR/WTL/PHD/PWD/PDY/2025/W-1191(Annexe)

Date: 05.11.2025

TEST REPORT- CHEMICAL

Customer Name & Address : Vivekanandha Vidyalaya,
Sellaperumalpet, Lawspet, Puducherry - 605008.

Customer Reference : Letter dt.04.11.2025

SAMPLE DETAILS

SAMPLE DETAILS	
Sample Code : 2025/W-1191	Information provided by the Customer
Product Category : Water	Sampled on : 04.11.2025
Sample Name : Drinking Water	Sample Description : Treated Water
Sample Condition : Fit for analysis	Sample Source : --
Sampled by : Customer	Identification by Customer : Sample - V
Sample Received on : 04.11.2025	
Test Started on : 04.11.2025	Sampling Location : School Campus, Sellaperumalpet,
Test Completed on : 05.11.2025	Lawspet, Puducherry.

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	156	500 Max	2000 Max

.....End of Report.....


Authorized Signatory

L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PUDUCHERRY.

Copy submitted to:

The Executive Engineer,
PHD., PWD., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.